

## PRODUCT CLASSIFICATION FIRES CR-053/04 SAP

**Product:** Cable system with NIEDAX accessories  
**Sponsor:** RAMCRO s.r.l., Via Tanaro 19, 20010 Villastanza di Parabiago, Italy  
**Manufacturer:** RAMCRO s.r.l., Via Tanaro 19, 20010 Villastanza di Parabiago, Italy

It has been classified:

TYPE	RAMCRO CODE	CLASSIFICATION	
		Tray	Ceiling
E90CR3MIVE 2x1,5	SAR0214HFEMX-F3 SENZA FDV	E 90	E 90
E90CR3MI 2x1,5	SAR0214HFEMX-F3 SENZA FDV	E 90	E 90
E30CR3 2x1,5	SSR0214HUESX-F3 SENZA FDV	E 60	E 90
E30CR3VE 2x1,5	SSR0214HUESX-F3	E 90	E 90
E30GOSIVE 2x1,5	SSR0214HUEEX-F3	E 90	E 90

TYPE	RAMCRO CODE	CLASSIFICATION	
		Tray	Ceiling
E90CR3SCH 1x2x0,80	SAR0208HFEMX-F3 SENZA FDV	E 90	-
E90CR3VESCH 1x2x0,80	SAR0208HFEMX-F3	E 90	E 90
E30CR3VESCH 1x2x0,80	SAR0208HFESX-F3	E 60	E 60
E30GOSIVESCH 1x2x0,80	SAR0208HFEEX-F3	E 90	E 60

*Product was tested according to DIN 4102 12: 1998-11*

The course of the test is described in detail in the test report No.:

**FIRES FR 030/04 C (E)**

*Caution:*

- Classification is valid to 20. 4. 2009
- The field of application of the classification is specified on the reverse of this document
- Any modifications to the contents of this document may only be performed by FIRES s.r.o. Batizovce

Batizovce 20.04.2004  
Prepared by: Akuratný Juraj

Ing. Štefan Rástocký  
FIRES s.r.o. Batizovce