

Loss Prevention Certification Board



CERTIFICATE OF PRODUCT CONFORMITY

This is to certify

RAMCRO SRL

Via Tawaro, 19, 20010 Villastawza, Di Parabiago (M1), Italy

Ramfirecro-F3

(Refer to attached Appendix for details)

have complied with the requirements of the following:

BS 6387: 1994 – Performance requirements for cables required to maintain circuit integrity under fire conditions.

and achieved:

<0.5%HCl when tested in accordance with BS EN50267-2-1: 1999 – Method of test for Gases evolved during combustion of electric cables

Ramcro SRL is authorised to use the LPCB mark in association with the product(s) listed in this certificate


Certificate No. 568a Issue 1

Issued 27 October 2003

Valid Until 13 December 2004

Signed on behalf of the LPCB

R PHILLIPS



This Certificate is issued and held in force subject to the corresponding ISO 9000 certificate being maintained.

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel 01923 664100 Fax 01923 664603 www.brecertification.co.uk
This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.
To check the authenticity of this certificate, please visit our website or contact us.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE OF PRODUCT CONFORMITY NO. 568a

RAMCRO SRL

Ramfirecro-F3

LPCB Ref.No. 568a/01

Nominal csa of conductors (mm ²)	Core construction	BS 6387	BS EN50267-2-1 (outer covering)
1.0	Twin, 3 & 4	C, W, Z	<0.5%HCl
1.5	Twin, 3 & 4	C, W, Z	<0.5%HCl
2.5	Twin, 3 & 4	C, W, Z	<0.5%HCl
4.0	Twin, 3 & 4	C, W, Z	<0.5%HCl

Uo/U 300/500 V

Signed on behalf of the LPCB

R PHILLIPS

Page

1 of 1

Issued
Valid Until

27 October 2003
13 December 2004

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel 01923 664100 Fax 01923 664603 www.brecertification.co.uk
This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.
To check the authenticity of this certificate, please visit our website or contact us.